Certificate of Compliance

Certificate:	80239640	**Master Contract:**	305355
Project:	80239640	**Date Issued:**	2025-10-17
Issued to:	**Atlas Transformers India Limited** **Unit 2, Survey No. 47,** **Por, Ramangamdi ,** **District- Vadodara** **Vadodara, Gujarat 391243** **India** **Attention:** Varsha Pathak	**Issued by:**	*Leo Bian* Leo Bian

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

C US

PRODUCTS

Class 5411 06 TRANSFORMERS - Power
Class 5411 86 TRANSFORMERS - Power - Certified to US Standards

Dry type transformers, enclosed, AN (Air Naturally cooled) with k-factor 1, 4, 9, and 13:

Model(s)	Primary Voltage (VAC)	Secondary Voltage (VAC)	Power (kVA)	Frequency (Hz)	Phase	Insulation Class (°C)	Enclosure Type
AIA3	600 or 480 or 400	480 or 400 or 240 or 208 or 120	15, 30, 45, 75, 112.5, 150, 225, 300, 450, 500, 750, 1000 and 1500	60	3	220	3R

© 2025 CSA Group. All rights reserved.